BXUVC.W606 - FIRE-RESISTANCE RATINGS


BXUVC - Fire-resistance Ratings

See General Information for Fire-resistance Ratings

Design No. W606

September 24, 2018

Assembly Rating — 2 h




Cookies on UL

VERTICAL SECTION

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners.. Learn More

> Cookie Settings

√ Accept



- 1. **Flashing Channels** Channels 200 mm wide with 45 mm and 76 mm flanges fabricated from nominal 1.52 mm thick galvanized or aluminum-zinc alloy-coated sheet steel. Fastened to the frame with 6.4 mm by 41 mm anchors spaced 305 mm OC.
- 2(a). Interior Steel Liner Panels available in nominal 800 mm widths fabricated from nominal 0.61 mm thick galvanized or aluminum-zinc alloy-coated sheet steel. Fastened to flashing channels with 19 mm long sheet metal screws spaced 305 mm OC. Interlocking joints of adjacent panels sealed with factory-applied butyl caulking and secured with 19 mm long sheet metal screws spaced 305 mm OC. Butyl tape applied between the steel liner panels and the flashing channels to provide an air barrier.

OR

• 2(b). Wall and Partition Facings and Accessories — (CLBVC). Type L-800 panels of nominal 0.61 mm thickness. Fastened to flashing channels with 19 Cookies on UL mm long sheet metal screws spaced 305 mm OC. Interlocking joints of We use cookies to personalize adjacent panels sealed with factory-applied butyl caulking and secured with content and ads, to provide social media 19 mm long sheet metal screws spaced 305 mm OC. Butyl tape agree traffic, between the panels and the flashing channels to provide an air balabout YGGMEST IN our site with our social media, advertising and analytics partners.. Learn More

2/5

• 2(c). Wall and Partition Facings and Accessories — (CLBVC). Interior Steel Liner panels of nominal 0.61 mm thickness. Fastened to flashing channels with 19 mm long sheet metal screws spaced 305 mm OC. Interlocking joints of adjacent panels sealed with site-applied butyl caulking and secured with 19 mm long sheet metal screws spaced 305 mm OC. Butyl tape applied between the panels and the flashing channels to provide an air barrier.

3(a). **Z-Bar Sub-Girts** — Notched Z-bars 200 mm wide with 25 mm and 45 mm flanges fabricated from nominal 1.22 mm thick galvanized or aluminum-zinc alloy-coated sheet steel. Spaced a maximum of 1525 mm OC. Fastened to the steel liner panels with 19 mm long sheet metal screws spaced not more than 200 mm OC.

OR

• 3(b). **Z-Bar Sub-Girts** — (For use with items 2c and 6c) — Z-bars 200 mm wide with 45 mm flanges fabricated from nominal 1.22 mm thick galvanized or aluminum-zinc alloy-coated sheet steel. Spaced a maximum of 1525 mm OC. Fastened to the steel liner panels with 19 mm long sheet metal screws spaced not more than 200 mm OC.

REVETEMENTS METALLIQUES LUSSIER INC — Type Z-Bar No.200

4. **Ceramic Fibre Blanket** — Density 128 kg/m³, 13 mm thick, minimum 100 mm wide, attached to the Z-bar sub-girts with stick pins spaced 250 mm OC.

>

Cookies on UL

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. Learn More

1
1
1
1
i .
\$
1
L

• 5. Batts and Blankets — (BZJZC). Two layers of mineral wool batts, 610 or 813 mm wide by 1220 or 1525 mm long by 102 mm thick, designated "Roxul® Firewall 2HR". Mineral Fibre Insulation, minimum density 72 kg/m³, installed with joints staggered a minimum of 300 mm within each layer and between adjacent layers. The overall thickness of the wall may be increased provided the Mineral Fibre Insulation (item 5) is used to completely fill the wall cavity, and provided the size of the Flashing Channels (item 1) and Z-Bar Sub-Girts (item 3) are increased to match the thicker wall.

6(a). **Exterior Cladding and Accessories** — Corrugated panels, available in various profiles and nominal 915 mm widths, fabricated from nominal 0.61 mm thick galvanized or aluminum-zinc alloy-coated sheet steel. Fastened to the Z-bar sub-girts with minimum 19 mm long sheet metal screws spaced 305 mm OC. Fastened to flashing channels with 19 mm long sheet metal screws spaced 305 mm OC. Side lap joints of adjacent panels fastened with 19 mm long sheet metal screws spaced 405 mm OC. The top and bottom of the exterior cladding are trimmed with cap and drip flashings respectively.

OR

• 6(b). Wall and Partition Facings and Accessories — (CLBVC). Type CL 725, CL7040, CL840, CL38, CL938, CL3070, CL470, CL306, CL308, CL3100 or CL400 corrugated panels of nominal 0.61 mm thickness. Fastened to the Z-bar subgirts with minimum 19 mm long sheet metal screws spaced 305 mm OC. Fastened to flashing channels with 19 mm long sheet metal screws spaced 305 mm OC. Side lap joints of adjacent panels fastened with 19 mm long sheet metal screws spaced 405 mm OC. The top and bottom of the exterior cladding are trimmed with cap and drip flashings respectively.

Cookies on UL

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. Learn More

OR

• 6(c). Wall and Partition Facings and Accessories — (CLBVC). Exterior Steel Cladding panels of nominal 0.61 mm thickness. Fastened to the Z-bar subgirts with minimum 19 mm long sheet metal screws spaced 305 mm OC. Fastened to flashing channels with 19 mm long sheet metal screws spaced 305 mm OC. Side lap joints of adjacent panels fastened with 19 mm long sheet metal screws spaced 405 mm OC. The top and bottom of the exterior cladding are trimmed with cap and drip flashings respectively.

REVETEMENTS METALLIQUES LUSSIER INC — Types 625-42B, 36-150A, 36-150B, T-1000A, T-1000B and 5/8 Corrugated

Last Updated on 2018-09-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice the following format: "© 2018 UL LLC".

UL and the UL logo are trademarks of UL LLC ©2018 All Rights Reserved.

About Privacy Policy Terms & Conditions Access Your Data

Cackies on UL

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners.. Learn More